

Generator Set Data Sheet

Model: C22 D5

Frequency: 50

Fuel Type: Diesel

Document Number	DS10-cpgk-RevA
Spec Sheet:	SS2-CPGK
Noise Data Sheet (Open / Enclosed):	ND50-OS550 / ND50-CS550
Airflow Data Sheet:	AF50-550
Derate Data Sheet (Open / Enclosed):	DD50-OS550 / DD50-CS550
Transient Data Sheet:	TD50-550

Fuel Consumption	Standby kW (kVA)		Prime kW (kVA)					
Ratings	17.6 (22)			16 (20)				
Load	1/4	1/2	3/4	Full	1/4	1/2	3/4	Full
US gph	0.3	0.6	0.9	1.2	0.3	0.6	0.8	1.1
L/hr	2	3	4	6	2	3	4	5

Engine	Standby Rating	Prime Rating	
Engine Manufacturer	Cummins		
Engine Model	4B3.3G1		
Configuration	4 Cycle; In-line;	4 Cylinder Diesel	
Aspiration	Naturally	Aspirated	
Gross Engine Power Output, kWm	36	32	
BMEP at Set Rated Load, kPa	876	787	
Bore, mm	ç	5	
Stroke, mm	1	15	
Rated Speed, rpm	15	500	
Piston Speed, m/s	5	.8	
Compression Ratio	18	.2:1	
Lube Oil Capacity, L	7		
Overspeed Limit, rpm	1800 ±50		
Regenerative Power, kW	3		
Governor Type	Mechanical		
Starting Voltage	12 Volts DC		
Fuel Flow			
Maximum Fuel Flow, L/hr	12	2.5	
Maximum Fuel Inlet Restriction, mm Hg	7	/3	
Maximum Fuel Inlet Temperature (°C)	60		
Air			
Combustion Air, m³/min	2.1	2.1	
Maximum Air Cleaner Restriction, kPa	6.2		
Exhaust			
Exhaust Gas Flow at Set Rated Load, m³/min	5.7	5.4	
Exhaust Gas Temperature, °C	498	448	
Maximum Exhaust Back Pressure, kPa	10	0.2	



Standard Set-Mounted Radiator Cooling	Standby Rating	Prime Rating
Ambient Design, <sup>°</sup> C	50	)
Fan Load, KW <sub>m</sub>	0.7	7
Coolant Capacity (with Radiator), L	9.1	
Cooling System Air Flow, m3/min @ 12.7mmH2O	0.9	2
Total Heat Rejection, BTU/min	1230	1180
Maximum Cooling Air Flow Static Restriction mmH2O	12.	7


## Open Set Derating Factors Kw (kVA).

Note: Standard open genset options running at 400V, 150m above sea level. For enclosed product derates, please refer to datasheet - DD50-CS550.

	27°C	40°C	45°C	50°C	55°C
Standby	17.6 (22)	17.6 (22)	17.5 (21.9)	16.9 (21.1)	16.4 (20.5)
Prime	16 (20)	16 (20)	15.9 (19.9)	15.4 (19.3)	14.9 (18.6)

Weights*	Open	Enclosed
Unit Dry Weight kgs	544	868
Unit Wet Weight kgs	731	1055

\* Weights represent a set with standard features. See outline drawing for weights of other configurations



\*Note: Outlines are for illustrative purposes only. Please refer to the genset outline drawing for exact representation of this model.

www.cumminspower.com

© 2004-2006 | Cummins Power Generation | Specifications Subject to Change Without Notice

Cummins and PowerCommand are registered trademarks of Cummins Inc. AmpSentry is a trademark of Cummins Inc.



Alternator Data					
Feature Code		Temp Rise Degrees C	Duty <sup>2</sup>	Alternator	Voltage
B729	Wye, 3 Phase	150/125C	S/P	BC164E	380-440V
					L

## Notes:

Ratings Definitions		
Standby:	Prime (Unlimited Running Time):	Base Load (Continuous):
rating is only applicable to variable loads with an average load factor of 80 percent of the standby rating for a maximum of 200 hours of operation per year and a maximum of 25 hours per year at	load for an unlimited number of hours. A 10% overload capability is available for limited time. (Equivalent to Prime Power in accordance with ISO8528 and Overload Power in accordance with ISO3046, AS2789, DIN6271, and BS5514). This rating is not applicable to all generator set models.	for unlimited hours. No sustained overload capability is available for this rating. Consult authorized distributor for rating. (Equivalent to Continuous Power in accordance with ISO8528, ISO3046, AS2789, DIN6271, and

1. Limited single phase capability is available from some three phase rated configurations. To obtain single phase rating, multiply the three phase kW rating by the Single Phase Factor<sup>3</sup>. All single phase ratings are at unity power factor.

2. Standby (S), Prime (P) and (C) Continuous ratings.

- 3. Factor for the Single Phase Output from Three Phase Alternator formula listed below
- 4. Maximum rated starting kVA that results in a minimum of 90% of rated sustained voltage during starting.

## Formulas for calculating full load currents:

Three Phase Output	Single Phase Output
kWx1000	kWxSingleP haseFactor x1000
Voltagex1.73x0.8	Voltage

## See your distributor for more information.

Cummins Power Generation Manston Park, Columbus Avenue Manston, Ramsgate Kent CT12 5BF, UK Telephone: +44 (0) 1843 255000 Fax: +44 (0) 1843 255902 E-Mail: cpg.uk@cummins.com Web: www.cumminspower.com Cummins and PowerCommand are registered trademarks of Cummins Inc. AmpSentry is a trademark of Cummins Inc. Our energy working for you.™

www.cumminspower.com © 2004-2006 | Cummins Power Generation | Specifications Subject to Change Without Notice Cummins and PowerCommand are registered trademarks of Cummins Inc. AmpSentry is a trademark of Cummins Inc.